

District Level water Testing Laboratory Darbhanga DLWTL
Government of Bihar
Public Health Engineering Department

District Name: Darbhanga
Sample Code - 02

Sample collected by : Nikhil Kumar
Sample Collected On-2/06/2025

District Name: Darbhanga

Sample Code - 02

Sample Collected On: 20/6/2025

SL. No.	Block	Panchayat	Village	Location of Source	pH	Turb.	EC	TDS	TH	Ca	Parameters										Total Coli	Remarks
											Mg	Cl	Alka.	Fe	NO3	SO4	F	As				
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	20		
1	Sadar	Loam	Givechh Ghat, Opposite Tata Motors Showroom	Birla Open Minds Inter National School Darbhanga	7.68	NT	566	368	184	48	15.36	76	202	NT	NT	NT	NT	NT	NT	NT		
Desirable limit					6.5	5.0	-	500	200	75	30	250	200	0.3	45	25	1.0	0.01		-		
Permissible limit					8.5	10.0	-	2000	600	200	100	1000	600	1.0	NR	400	1.5	NR	**	-		

Priyanka Rai
Principal
Birla Open Minds International School
Darbhanga

Alok Rayan
Manager
Birla Open Minds International School
Darbhanga

[Signature]
Chemist
2/06/25
P.H Division Darbhanga